




Type Approval Certificate

Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	1225898 HH
Company	Camille Bauer AG Aargauerstrasse 7 CH-5610 Wohlen
Product Description	Transducer for Current
Type	SINEAX I 538, SINEAX I 542, SINEAX I 552
Environmental Category	C
Technical Data / Range of Application	SINEAX I 538: power supply 24 V DC or 230 V AC Input: 0 - 0.8 A up to 0 - 6 A AC Output: 0 - 20 mA or 4 - 20 mA or 0 - 5 V, 1 - 5 V, 0 - 10 V or 2 - 10 V SINEAX I 542: without power supply Input: 0 - 1 A / 5 A or 0 - 1.2 A / 6 A Output: 0 - 5 mA, 0 - 10 mA or 0 - 20 mA SINEAX I 552: power supply 24 - 60 V or 85 - 230 V AC / DC Input: 0 - 0.1 A / 0.5 A to 0 - 1.2 A / 6 A Output: 0 - 20 mA or 4 - 20 mA or 0 - 5 V, 1 - 5 V, 0 - 10 V or 2 - 10 V Degree of protection: IP 20 DIN - rail snap on connection
Test Standard	Regulations for the Performance of Type Tests Part 1, Edition 1997, EMC2
Documents	Test report : I 538, I 542, I 552 Circuit diagram: Dossiers E250, E251, E247 Data sheet: I538 Lx, I 542 Lx, I 552 Lx
Remarks	None
Valid until	2008-07-29
Page 1 of 1	Type Approval Symbol 
File No. I.D.15	
Hamburg, 2004-03-03	

Germanischer Lloyd

W. Voß

Th. Reimer

This certificate is issued on the basis of "Regulations for the Performance of Type Tests, Part 0, Procedure".